



ITPENERGISED

PART OF  SLR



Port Dundas BESS – Outline Battery Storage Safety Management Plan

Technical Report

Client:	Fig Power Ltd
Project/Proposal No:	7645
Version:	1.7
Date:	2025-02-07

Document Information

Project Name:	Port Dundas BESS – Outline Battery Storage Safety Management Plan
Document Title:	Technical Report
Client Name:	Fig Power Ltd
Client Contact:	Alba Vega Escamilla, Laura Garcia de Dios
Client Address:	Generator Building, Counterslip, Britol, BS1 6BX
Document Status:	Final for Issue
Author:	David Fernandez
Reviewed:	Kerri McGuire
Approved:	[Add approved name e.g. J. Doe]
Date:	2025-02-07
Version:	1.7
Project/Proposal Number:	7645
ITPenergised Office:	4th Floor, Centrum House, 108-114 Dundas Street, Edinburgh, EH3 5DQ

Revision History

Version	Date	Authored	Reviewed	Approved	Notes
1.1	2024-10-18	D Fernandez	T Ahmad, A Adejumo	G Bollan	First Issue
1.2	2024-06-11	D Fernandez	Kerri McGuire		Second Issue with incorporation of Client Comments
1.3	2024-18-11	D Fernandez			Third Issue including updated correspondence from SFRS
1.4	2024-29-11	D Fernandez	Kerri McGuire		Forth Issue including missing figure 1.1 and revision of section 6.2.
1.5	2025-31-01	D Fernandez	Kerri McGuire		Forth Issue including tables in sections 6.2. and 6.3. and completion of pending information.
1.6	2025-07-02	D Fernandez	Kerri McGuire		Final commentary of water supply and spare containers considerations.

© Copyright 2025 ITPenergised. The concepts and information contained in this document are the property of Energised Environments Limited, ITPE Ltd and Xero Energy Limited, trading as ITPenergised. Use or copying of this document in whole or in part without the written permission of ITPenergised companies constitutes an infringement of copyright unless otherwise expressly agreed by contract.

Limitation: This document has been prepared solely for the use of the Client and any party with whom a warranty agreement has been executed, or an assignment has been agreed. No other parties may rely on the contents of this document without written approval

from ITPEnegised for which a charge may be applicable. ITPEnegised accepts no responsibility or liability for the consequences of use of this document for any purpose other than that for which it was commissioned, nor the use of this document by any third party with whom an agreement has not been executed.

The contents of this document are confidential to the intended recipient and may not be disclosed without their express consent. If received in error, please delete it without making or distributing copies. Opinions and information that do not relate to the official business of Energised Environments Limited registered at 93 South Woodside Road, Glasgow, G20 6NT or ITPE Ltd., registered at Brew House, Jacob Street, Tower Hill, Bristol, BS2 0EQ, or Xero Energy Limited, registered at 93 South Woodside Road, Glasgow, G20 6NT trading as ITPEnegised, are not endorsed by the company or companies.

Contents

Document Information	2
Contents	4
1. Introduction	5
1.1 Scope	5
1.2 Site Description	5
2. Project Requirements	7
2.1 BESS Technology	7
3. Safety Standards for Li Ion Battery Technology	10
3.1 Battery Cells and Modules	10
3.2 BMS	10
3.3 PCS/Battery Inverters	11
3.4 Energy Management System (EMS)	11
3.5 Fire Detection and Suppression Systems	11
3.6 Enclosures	12
3.7 Cabling and Electrical Connections	13
3.8 Cooling and Ventilation Systems	13
4. Operation and Maintenance Requirements	14
4.1 Operational Requirements	14
4.2 Maintenance Requirements	14
5. Fire and Rescue Services Consultation	17
6. BESS Design Layout	18
6.1 Description	18
6.2 Design Guidelines	18
6.3 Design Review of Proposed Development layout from Fire Safety Perspective	21
Appendix 1 Email Correspondence with FRS Department	23

1. Introduction

1.1 Scope

The purpose of this document, the Port Dundas Outline Battery Storage Safety Management Plan (OBSSMP), is to describe the guidelines and best practice for safe operation of a large-scale Battery Electric Storage System (BESS). The purpose of this document is to identify, assess, and mitigate fire safety risks associated with the installation and operation of the BESS.

It should be noted that when detailed design will be undertaken and prior to commencement of the BESS project construction, a Battery Storage Safety Management Plan (BSSMP) will need to be developed with the latest good practices for battery fire detection and prevention including an emergency response plan. The planned operational date for the BESS is 31st March 2033, however the developer Fig Power is aiming for an accelerated grid connection by May 2028. The BSSMP would need to be developed in line with the most up to date standards, guidelines and good practices described in the OBSSMP. Early engagement with the local planning authorities and relevant regulatory bodies will be crucial.

1.2 Site Description

A Battery Energy Storage System (BESS) scheme is proposed at Port Dundas in Glasgow, at the site currently occupied by Breedon Concrete Plant. The site is located within the Craighall Business Park and is accessed from Mary Street, connecting to High Craighall Road. The site is located directly to the South of the existing Port Dundas substation (see Figure 1-1). The site is surrounded by commercial and industrial units associated with the business park. There are residential dwellings to the east of the site, forming part of the wider Dundashill Masterplan.



Figure 1-1: Port Dundas Site

Port Dundas is an historic area in Glasgow in Scotland, previously known for industrial activities. As part of the UK's transition plans to renewable energy, the National Grid operator aims to enhance the resilience and flexibility of the electricity system to ensure its stability while transitioning to a low-carbon future. BESS play a crucial role by storing surplus electricity generated by renewable technologies and releasing when demand spikes; BESS also contribute managing the intermittency of renewable energy technologies.

Fig Power has produced a Battery Energy Storage System (BESS) layout showing the arrangement of battery container, Power Conversion Systems (PCS), access road and switchgear. The storage scheme involves a 90MW power BESS with 2hours of storage capacity, thus 180MWh of BESS capacity. Further information can be found under Section 6 on the design. For the current design the technical datasheets of battery cell and ESS Hithium ∞ Container Block have been provided. The battery technology is based on prismatic lithium iron phosphate (LFP) cells, a type of lithium-ion battery technology known for its stability, safety, and longevity. Section 2.1 includes further information on the BESS technology.




Figure 1-2: Port Dundas BESS Layout

1.2.1 National Policy Alignment

NPF4 is the Scottish Government's long-term spatial planning framework, integrating national policy on land use and sustainable development. According to the NPF4, BESS projects play a crucial role in realising UK's objective of transition towards a more sustainable energy system. Policy 9 supports the re-use of brownfield land and policy 11¹ explicitly support all forms of renewable energy generation and emphasise the importance of energy storage; specifically:

- Policy 9: supports the sustainable reuse of brownfield land including vacant, derelict land and empty buildings.
- Policy 11 (Energy): confirms that development proposals for all forms of renewable, low carbon and zero emissions technologies will be supported. The policy requires development proposals to maximise net economic impact, including local and community socio-economic benefits.

¹ <https://www.gov.scot/publications/national-planning-framework-4/pages/3/>

2. Project Requirements

For the development of a utility scale BESS project, it is essential to specify project requirements to ensure successful planning, design, construction, and operation. This section will describe the fundamentals of BESS, the cell technology, main system components that typically comprise a BESS system (battery container, PCS, cooling system, fire suppression system and control), and listing of standards.

Prior to commencement of construction of the BESS, a BSSMP (in accordance with this Outline BSSMP) is required to be prepared and submitted to the relevant local planning authority and approved, in consultation with the HSE and Scottish Fire and Rescue.

2.1 BESS Technology

2.1.1 Fundamentals

Lithium-ion (Li-ion) batteries have become a dominant rechargeable energy storage technology due to their high energy density, long lifespan, and lightweight nature. They are widely used in consumer electronics and electric vehicles as well as larger scale stationary energy storage applications.

Li-ion batteries function by moving lithium ions through an electrolyte between an anode and cathode during charging and discharging. The anode is typically made from graphite, and the cathode is composed of a lithium-based material. During discharge, lithium ions move from the anode to the cathode, releasing energy. The key components of a Li-ion cell are:

- Anode: Typically graphite or silicon;
- Cathode: Composed of various materials, in this case lithium iron phosphate (LiFePO₄);
- Separator: Avoids direct contact between anode and cathode, allowing only ions to pass through; and
- Electrolyte: A lithium salt dissolved in an organic solvent. LFP is less susceptible to thermal runaway than chemistries like Nickel Manganese Cobalt (NMC). and has better thermal and chemical stability and does not decompose at higher temperatures. LFP represented about 60% of the UK BESS market share in 2022.

2.1.2 System Components

The main components typically found in a BESS are as follows:

- Batteries: The battery is composed of single cells, which can be arranged e.g. into battery modules or battery packs.
- Power Conversion System (PCS): The PCS is a bi-directional inverter that converts direct current (DC) stored by the batteries to alternating current (AC) for the grid, or AC from the grid to DC for charging the batteries. It is a critical system component that controls battery charge and discharge based on internal communication protocols.
- Battery Management System (BMS): This component is responsible not only for the correct operation but as well for the safe functioning of the battery. The BMS maintains each battery cell within the required operational voltage, current and temperature range. The BMS also estimates the State of Charge (SoC) and State of Health (SoH) of the battery.
- Energy Management System (EMS): The EMS is responsible for the control of the BESS and plays a crucial role in managing the charging and discharging process with the purposes of optimising system performance and BESS longevity, amongst others.

- **Safety Systems:** These includes systems such as cooling and heating, air conditioning, fire suppression, smoke detection, etc. A monitoring and control system will be responsible for the safe operation of the BESS and prevent fire or other hazardous events. The BESS will also normally include a CCTV system.




Figure 2-1: Battery

2.1.3 Safety Systems

This section provides a description of the safety systems required and integrated in a large-scale battery project. The BESS does require a comprehensive safety system that contributes to safe operational conditions and minimises potential risks such as thermal runaway², fires or system failures.

2.1.3.1 Battery Management System (BMS)

The BMS is the primary safety and control mechanism in a BESS. The BMS is required to monitor and manage the battery cells to ensure optimal operation and safety. By controlling the battery's key parameters in real-time, the BMS protects the system from dangerous conditions such as overvoltage, undervoltage, and overheating. The parameters controlled by the BMS include the following:

- **Temperature monitoring:** The continuous measurement of cell temperatures to prevent potential overheating issues that could derive to thermal runaway.
- **Voltage and current monitoring:** This ensures each battery cell operates within a safe voltage range but also monitors current to avoid potential overcharging or discharging.
- **State of Charge (SOC) and Health (SOH) monitoring:** The monitoring and control of the SOC and SOH to ensure long battery life and prevent potential deep discharges or overcharging.
- **Cell Balancing:** The aim is to ensure uniform performance across all cells, thus minimising risks of premature degradation of weak cells or other system imbalances that may occur.

2.1.3.2 Thermal Management System (TMS)

The TMS is responsible for controlling the temperature of the battery at pack level. This system is required to prevent overheating issues and ensure the battery pack operates in a safe temperature range to minimise thermal runaway risks. The BESS TMS shall include:

- **Active cooling:** This involves air or liquid cooling systems to dissipate heat during charging and discharging cycles. Liquid cooling for BESS is becoming the established technique due to advantages in cooling efficiency, enhanced thermal management, improved safety, etc.
- **Passive cooling:** Includes heat sinks, ventilated enclosures, and other passive mechanisms to distribute heat naturally.

² Thermal runaway definition: A condition where the heat generated inside a battery exceeds the ability of the BESS cooling system to dissipate that heat.

- Temperature sensors: Located throughout the BESS to detect local temperature spikes.
- Thermal insulation: This reduces the effect on the BESS of high external temperatures.

2.1.3.3 Fire Suppression System (FSS)

The FSS must be integrated into BESS enclosures and is designed to detect, control, and extinguish fires before they propagate, especially under a potential thermal runaway scenario. A rapid response from the suppression system helps prevent fire spreading to other cells or modules. The FSS shall provide:

- Smoke and Fire Detection: This will allow the early detection of smoke, temperature spikes, and gas emissions to trigger alarms or suppression mechanisms.
- Fire Suppression: This involves an automatic fire suppression system employing chemical extinguishing agents (e.g. Novec 1230) or/and water mist systems designed to suppress Li-ion battery fires. The system shall be designed to act quickly and be compatible with the operation of electronic equipment within the BESS container.
- Gas Ventilation: The BESS may be equipped with a gas exhaust system to remove hazardous gases that may have been generated in a thermal runaway event which generally include hydrogen. This will reduce the risk of potential explosions.

2.1.3.4 Gas Detection and Ventilation System

The system is required to detect hazardous gases that could be emitted during a thermal runaway event or other potential system failures. The system will safely extract the generated gases from the BESS enclosure to outside air. This will avoid the buildup of potentially flammable or toxic gases in the BESS container, reducing the risk of explosion or harm to personnel. The system features shall be as follows:

- Gas Detection System: These are installed to detect various gases including hydrogen, carbon monoxide, or toxic electrolytes released when battery cells fail.
- Ventilation System: The system is automatically activated and ventilates dangerous gases to ensure that a hazardous environment does not develop within the container.
- Pressure Relief System: If excessive pressures are reached within the battery enclosure, the pressure relief system is activated to reduce the risk of a potential explosion.

2.1.3.5 Battery Enclosure

The BESS enclosure is designed to protect the battery system against mechanical damage, from external environmental hazards and unauthorised access. The enclosure features shall include:

- Weatherproof and Fireproof Enclosures: The protection of the BESS from external environmental factors such as wind, fire, rain and extreme temperatures.
- Explosion-Proof Enclosure: The enclosure must be able to contain potential explosions that occur within its enclosure in the event that vapors, gases, dust, or other flammable substances are ignited;
- Security System: This includes controls, alarm and surveillance to protect the system from tampering or unauthorised access.

2.1.3.6 Alarm and Emergency Shutdown System (AESS)

The AESS is required for automatic system shutdown under critical failure or hazard. The principle is to prevent further damage or potential hazard in the event of an emergency by stopping the system operations, thus mitigating the risk to personnel and equipment. The system shall be equipped with the following:

- Manual Emergency Shutdown System: Provides a manual shutdown mechanism for operators to safely power down the system in an emergency.
- Shutdown System: The system can automatically shut down if it detects critical issues identified by the real time monitoring, such as overheating, overvoltage, or fire.

- Alarms System: Immediate alerts are sent to operators and emergency responders when a failure or dangerous condition is detected.

3. Safety Standards for Li Ion Battery Technology

The Port Dundas BESS development must comply with several standards and certifications for safe and resilient operation. The current design standard for BESS facility is the latest edition of UL 9540, currently from 2023. It should be noted that currently the NFPA 855 (2023) represents a guideline for the design and installation of BESS. The Grid Scale Battery Energy Storage System planning - Guidance for FRS³ (2023) was also considered.

Compliance with relevant safety standards at component level is essential for mitigating risks such as electrical faults, thermal runaway, fire and explosion. A summary list of safety standards for the main components of BESS has been produced.

Please note that the standards described in this section and this document may be superseded by future standards and versions.

3.1 Battery Cells and Modules

The battery modules shall demonstrate compliance with following standards:

- UL 9540A: This involves tests for thermal runaway propagation to ensure that the fire risk within a module or between battery cells is minimised and contained. This standard demonstrates that thermal runaway propagation does not spread between modules generating potentially explosive gases, such as hydrogen for Li-ion cells. This would otherwise result in a potential hazard for the battery container's integrity.
- UL 1973: This covers safety for stationary battery systems, testing for mechanical integrity, electrical faults (overvoltage, overcurrent), and thermal fatigue in Li-ion cells.
- IEC 62619: International standard for rechargeable battery safety in industrial applications, focusing on preventing thermal runaway, overcharging, and electrical safety.
- UN 38.3: Transportation safety standard, ensuring that Li-ion batteries can safely withstand mechanical shocks, pressure, and temperature extremes during transit.

3.2 BMS

The BMS shall demonstrate compliance with following standards:

- UL 991: Safety standard for BMS electronics, ensuring reliable fault detection and protection features such as voltage, current, and temperature monitoring.
- UL 1998: Software reliability standard, ensuring that BMS software handles charging and discharging functions and operates safely under all conditions.
- IEC 61508: Functional safety of electrical, electronic, and programmable systems, ensuring that the BMS follows safety protocols for fault tolerance and system shutdown in critical situations.
- IEC 62040: Addresses safety and performance of power systems, ensuring BMS integration with power conversion equipment.

³ FRS stands for Fire Rescue Service

3.3 PCS/Battery Inverters

The PCS is a fundamental component managing the energy flow between the battery, the electrical grid, and the connected loads. The PCS enables efficient charging and discharging of the batteries, converting power between alternating current (AC) and direct current (DC), and ensuring seamless interaction between the storage system and the grid or end users. The PCS shall demonstrate compliance with key standards including:

- UL 1741: Governs the safety of inverters for distributed energy resources, including BESS. It focuses on preventing electrical faults, such as overvoltage and ground faults.
- IEC 62109: Ensures the safety of inverters by addressing electrical shock prevention, thermal management, and insulation resistance.
- IEEE 1547: Specifies the requirements for connecting the BESS to the utility grid, ensuring the inverter safely synchronizes with and disconnects from the grid during faults or outages.
- IEC 62116: This standard refers to anti-islanding protection methods to ensure PCS disconnect from the grid in case of a power outage, preventing unintentional islanding.
- IEC 61000: This standard refers to electromagnetic compatibility (EMC), covering emission and immunity requirements.
- ISO/IEC 27001: This standard is not specific to PCS but outlines best practices for information security management systems (ISMS). With increasing digital control and remote operation of BESS systems, PCS components need to be secured against cyber threats. Compliance with cybersecurity protocols ensures data integrity and protects the system from unauthorised access.
- IEC 61850: This standard defines communication protocols for substation automation systems and is widely adopted for smart grid applications. It ensures secure and standardised communication between the PCS and other grid components.

3.4 Energy Management System (EMS)

The EMS shall demonstrate compliance with following standards:

- IEC 62443: Ensures cybersecurity for industrial automation systems, including EMS, to prevent cyberattacks that could disrupt BESS operations.
- ISO 27001: Focuses on information security management, ensuring that the EMS can protect critical operational data.
- IEC 61508: Functional safety for EMS systems to ensure that safety-critical processes within the BESS, such as dispatching power and controlling inverters, are reliable.

3.5 Fire Detection and Suppression Systems

The fire detection systems shall demonstrate compliance with following standards:

- NFPA 855: Provides fire safety requirements for the installation of energy storage systems, including Li-ion BESS, such as fire separation distances, suppression system requirements, and emergency planning.
- UL 9540: Focuses on system-level safety for energy storage systems, including fire protection measures for electrical components and enclosures.
- UL 9540A: Tests the system's ability to handle thermal runaway and limit fire propagation within and between battery modules.
- FM Global Datasheet 5-33: Offers guidelines for fire protection and hazard mitigation specific to Li-ion battery systems, including guidance on suppression systems for large battery arrays.

- Grid Scale Battery Energy Storage System planning - Guidance for FRS (2023) states that gaseous suppression systems have been proposed in the past. However, it indicates that based on research studies the installation of water-based suppression systems for fires involving cell modules are more effective.
- FM Global Research: States that cooling of the surroundings under a fire event is critical to protect the surrounding infrastructure but as well because it is currently not possible to extinguish a BESS fire with sprinklers. Furthermore, gaseous protection systems do not provide cooling of the ESS or the surrounding occupancy.

For the selection of the fire suppression system, in addition to the standards and compliance requirements, it is essential to base the choice on thorough risk assessments, environmental considerations, and the specific operational needs of the facility. The following aspects will need to be considered:

- Involvement of Fire Protection Engineer (FPE) who has experience in fire suppression systems, particularly for large scale BESS as is the case in Port Dundas.
- Calculation of the water supply requirements to ensure the flow rates and volumes needed for the type of suppression system selected and the potential for fire spread and the required coverage area. It shall be noted that the lack of sufficient water supplies at a particular site location should not be considered as the basis for a suppression system choice. The consideration of alternative solutions would need to be investigated.
- The water run-off management from the suppression system and its impact on the surrounding environment such as water sources, soil and nearby ecosystems. The investigation of measures to minimize potential environmental impacts would need to be assessed, e.g. containment basins or filtration systems. This must be detailed in the Emergency Response Plan.

3.5.1 Note on BESS without Fire Suppression System

Contemporary thinking on fire suppression strategies focuses on controlling and containing fire risks without necessarily relying on automatic fire suppression systems inside the BESS cabinets. The principle is to allow

a controlled burn-out of the battery cells or modules. This minimises the risk related to live battery modules that could still hold energy after a fire event, known as “stranded energy”. This facilitates the handle and disposal of the damaged battery cells or modules after the fire incident. For this design approach, the decommissioning process is simplified because there is no need to dispose of water or chemical suppression agents that might have been deployed during the fire suppression process.

Instead of an automatic suppression system, the BESS cabinets operate what is effectively a dry pipe sprinkler system. This type of system does not fill pipes with water unless activated, which makes it less prone to accidental discharge and water damage. Firefighters or emergency responders can then manually activate the dry pipe sprinkler system if they assess that internal suppression is necessary during a thermal runaway or fire event. This strategy allows human intervention, ensuring that suppression systems will only be deployed if judged to be required.

3.6 Enclosures

The enclosures shall demonstrate compliance with following standards:

- UL 9540: Governs the system-level safety of the entire energy storage system, ensuring enclosures protect components from environmental hazards and electrical faults.
- NFPA 68: This refers to the "Standard on Explosion Protection by Deflagration Venting," which focuses on designing systems to protect against explosions, specifically by allowing deflagration to vent safely without catastrophic damage to equipment or facilities.
- IEC 60529: Provides ingress protection (IP) ratings for electrical enclosures, determining resistance to water, dust, and accidental contact. For Port Dundas the BESS will be deployed outdoors and enclosures need to be highly protective.

- BS EN 13501-2: European standard for the fire resistance of building materials, ensuring BESS enclosures and partitions provide adequate containment during fire events.
- NFPA 855 requirement states that fire-rated barriers be established between the BESS units and adjacent areas:
 - 1-hour fire resistance rating for barriers within BESS installations or between individual BESS compartments; and
 - 2-hour fire resistance rating for walls separating BESS from other occupancies or critical infrastructure.

3.7 Cabling and Electrical Connections

The cabling and electrical connections shall demonstrate compliance with following standards:

- UL 6141: Safety standard for wiring and connections in energy storage and photovoltaic systems, ensuring proper insulation, grounding, and fault protection.
- NFPA 70 (NEC Article 690): The National Electrical Code (NEC) specifies installation standards for electrical systems, including battery connections and grounding, to prevent electrical fires and shock hazards.
- IEC 60502: International standard for medium-voltage power cables, addressing their performance and safety in energy systems.

3.8 Cooling and Ventilation Systems

The cooling and ventilation systems shall demonstrate compliance with following standards:

- **ASHRAE 90.1:** Standards for the energy-efficient design of buildings, including proper cooling and ventilation for energy storage systems to manage heat generated by Li-ion batteries.
- **NFPA 69:** Provides guidelines for prevention of explosion, focusing on managing gas buildup (e.g., hydrogen release from faulty Li-ion batteries) through proper ventilation and explosion venting systems. This standard focuses on preventing the explosion through methods like suppression, containment, inerting, or control of ignition sources.

UL 9540A: Includes testing for heat and gas management in energy storage systems to prevent explosions or fires caused by thermal runaway.

4. Operation and Maintenance Requirements

The Operation and Maintenance (O&M) for a BESS is crucial for both plant performance and safety. Methods and procedures impacting project safety must comply with up-to-date standards and regulations. Furthermore, O&M must contribute to optimal system performance and lifecycle; and maximise system availability through the minimisation of potential plant downtime.

4.1 Operational Requirements

The system operation shall be monitored to ensure optimal performance and identify any potential issues at an early stage. For the proposed BESS, the system shall monitor at least the following:

- Battery Management System (BMS) Operational Monitoring:
 - Ensure that battery cells and modules track the State of Charge (SoC), State of Health (SoH) and operating battery cell temperatures.
 - Ensure the system operates within safe voltage and current limits.
- Energy Management System (EMS) Operational Monitoring:
 - Monitoring of the charge discharge cycling to optimise system efficiency and revenue (e.g. energy arbitrage, frequency regulation, peak shaving).
 - Monitoring and control of the interaction between the BESS and the grid to ensure that the BESS provides the contracted grid services without compromising battery health.
- Remote Monitoring and Alerts: Provision of remote monitoring capabilities so that operators receive real-time alerts and can monitor plant status. This shall include an automatic monitoring system of key safety parameters such as: cell / module overheating warnings, deep charge/discharges of the battery or system failures (e.g. the cooling system).

4.2 Maintenance Requirements

4.2.1 Preventive Maintenance

Preventative maintenance for BESS requires scheduled, proactive actions to minimise the potential risk of plant failures, extension of system lifetime and contribute to system performance. This will result in a reduction of unplanned downtime, reactive repair needs, less frequent component replacements, and improve plant reliability and system efficiency. The preventative maintenance regime shall regularly require at least the following:

- Battery System:
 - Visual examination: Periodical visual checks to identify potential damage, leakages or corrosion.
 - Thermal Inspection: Use of infrared thermography to identify potential hotspots, e.g. poor electrical connections.
 - Capacity Testing: This involves regular discharge tests to check the battery capacity and actual performance, ensuring the system still meets the expected energy output. The BS EN 62620 standard specifies the requirements for large scale Li-ion BESS in terms of capacity testing, safety, and battery performance. As an example, if a BESS system participates in the UK's Capacity Market, it is a typical requirement to provide yearly capacity tests and performance tests to demonstrate that the system can deliver the capacity for which it has been contracted.

- Regular cleaning: This is to ensure that that battery terminals and general connections are clean to avoid poor connections.
- PCS
 - Battery inverter testing: The regular testing and recalibration of the inverters to guarantee the system efficiency and operational safety.
 - Firmware Updates: Regular software updates to ensure new releases or bug fixes are applied.
 - Visual examination: Undertake inspections to identify potential damage to connectors, cables, connectors, etc.
- Cooling and HVAC System Maintenance
 - Air filters maintenance: Ensure filters are regularly cleaned or replaced to guarantee optimal cooling performance.
 - Fans and Ventilation System Inspection: Inspect ventilation fans and airflow paths for blockages and ensure proper air circulation.
 - Coolant Levels: For liquid cooling systems, verify coolant levels and test for potential system leaks.
- Fire Suppression System Maintenance
 - Functional System Testing: This involves periodical fire tests to verify that the system performs as expected.
 - Smoke and Gas Detectors Testing: This involves periodical tests to verify early detection of any hazardous situations.
 - Alarm system testing: This involves periodical tests to confirm the alarm notification is triggered under a potential fire event.

4.2.2 Corrective Maintenance

This refers to the activities that are undertaken to rectify or address system failures or faults that have been identified. This may include:

- Battery Replacement or Reparation
 - Cell Replacement: Over time, batteries can degrade for several reasons such as usage, defects, environmental factors, etc. and therefore require repair or replacement.
 - Battery Rebalancing: This process ensures that individual cells within a battery pack have an equal voltage level, otherwise the discharging process is not uniform resulting in higher degradation of some cells compared to other and imbalances, thus reducing overall BESS capacity.
- Cooling System Repair
 - HVAC Unit Reparation: The repair or replacement of a failing HVAC to ensure that the BESS operates in the expected temperature range.
 - Leak Reparation: For liquid cooling systems, it is critical to resolve potential leaks that could result in overheating issues and electrical faults.

- PCS/Inverter Repairation
 - Electrical Faults: Correct any detected electrical faults, such as short circuits, ground faults, or voltage imbalances, in order to prevent damage to the BESS.
 - Fault Diagnosis: If the inverter is underperforming or failing then the inspection is required; causes may include firmware or hardware malfunctions. This may necessitate repairs or replacement of the faulty component.
- Compliance with Standards: The standards compliance contributes to the BESS safety, performance, and reliability:
 - Regulatory Inspections: This is to ensure that the BESS meets safety regulations, such as NFPA 855, UL 9540/9540A (for system safety testing), and IEC standards.
 - Environmental Compliance: This is to ensure the system meets environmental regulations regarding noise levels, system efficiency and materials disposal amongst others.
- Battery End-of-Life (EoL) Management: Determining the retirement of a BESS at EoL involves assessing several factors, including performance, safety, etc. Considerations include:
 - Monitoring of the BESS: As battery cells degrade over time this will track the capacity reductions and thus estimate when they should be potentially retired or replaced depending on the SoH.
 - Recycling Program: A proper recycling and disposal program should be developed in line with environmental regulations, this will contribute to the safe disposal of hazardous materials.
- Component Lifecycle Planning: Within a BESS each component has its own lifecycle, therefore it is fundamental to undertake careful component replacement planning. This will ensure that the full system operates optimally with minimal disruptions. The aim is to contribute to plant performance but also safety and plant reliability, e.g. inverter typically require replacement every 10-15 years, auxiliary systems like sensors, fuses, etc may have different life expectancies.

5. Fire and Rescue Services Consultation

The Scottish Fire and Rescue Service (SFRS) has been consulted for the Port Dundas project to ensure that their recommendations have been taken into consideration in the design layout of the proposed development. Their official response has been included below and full correspondence can be found in Appendix 1. Basically SFRS indicated that the recommendations will in future be provided once the relevant working group has concluded its work, to ensure consistency in the responses at national level. Until then, it is clearly stated that the NFCC guidance shall be followed⁴ which has already been considered in this document.

From: Travers, Paul <Paul.Travers@firescotland.gov.uk>

Sent: Wednesday, October 9, 2024 12:09 PM

To: David Fernandez <david.fernandez@itpenergised.com>

Cc: SFRS Water Planning <SFRS.WaterPlanning@firescotland.gov.uk>

Subject: RE: Battery Project Enquiry

Hi David SFRS are assessing all BESS site applications at the moment and there has been a working group established to consolidate all our departments and provide unified responses to all applications. Until this group completes its work, NFCC Best Practice guidance on BESS should be followed.

Regards Paul Travers

⁴ Grid Scale Battery Energy Storage System planning - Guidance for FRS (2023)

6. BESS Design Layout

6.1 Description

The proposed layout for the Port Dundas BESS is shown in Figure 6-1: Port Dundas BESS Layout (Drawing ref.: 000067-FIG-DR-0006_P03_Layout_Operation.pdf). The Figure shows a back to back design composed of 36 x 5MWh Hithium ∞ Container Block with 20 foot containers and a total of 18 Freemaq PCSK Power Electronics battery inverters with a combined power of 90MW. For each pair of containers (10MWh), an inverter has been assigned with a power rating of 5MW and a total of 8 Power Electronics Twin Skid and 2 Single Skid transformers for the connection to the 33kV Switchgear. The drawing allows for some spare space for future augmentation to mitigate, battery degradation.




Figure 6-1: Port Dundas BESS Layout (Draft ref: 000067-FIG-DR-0006_P03_Layout_Operation.pdf)

6.2 Design Guidelines

Table 6-1 lists the main BESS fire safety design guidelines and how the proposed development adheres to these.

Table 6-1: Listing of design requirements

Design Requirement	Adherence of the proposed design layout
The proposed layout involves a back-to-back layout design. As per NFPA (2023), if the space separation between enclosures is less than 6 metres then a thermal barrier rated at a minimum of 1 hour should be provided on the inside or outside of the enclosure.	The current design shows a 3.5m separation between pairs of containers, therefore the 1 hour thermal resistance barrier requirement (e.g., from the enclosure) will need to be included and it will be adhered to within the proposed development.

<p>The NFPA (2023) also states that the clearance to other structures than buildings may be reduced to 0.9 metres. However, the fire and explosion testing in accordance with UL9540A would then need to demonstrate that a fire within the BESS enclosure will not generate radiant heat flux sufficient to ignite stored materials in the surroundings or otherwise threaten the exposure.</p>	
<p>NFPA (2023) advises that the potential impact radius and therefore separation distance between a BESS and occupied buildings in case of a potential explosion event is at least 23 metres. Nevertheless, recommends increasing the clearance to 30.5 m. The Grid Scale Battery Energy Storage System planning - Guidance for FRS (2023)⁵ recommends an initial minimum separation distance of 25m prior to any mitigation measure such as blast walls.</p>	<p>For the current BESS layout the distance from the battery containers to the nearest buildings (the church building to the west and residential block of flats to the east) confirms it is greater than 30m.</p>
<p>The layout design shall consider the Grid Scale Battery Energy Storage System planning - Guidance for FRS (2023) which states that areas within 10 metres of the BESS units should be cleared of vegetation to minimise the risk of fire spreading.</p>	<p>For the proposed development the landscaping within the site boundary will primarily be kept to the site perimeter to follow the guidance, whilst still delivering biodiversity enhancement at the site.</p>
<p>The provision of two separate access points to the site is recommended, with the intention that at least one is upwind of the prevailing wind direction as per Grid Scale Battery Energy Storage System planning - Guidance for FRS (2023). Nevertheless, the 2024 FRS Draft Guidance that still needs to be released as a final version indicates it is preferable to have an alternative access point taking account of the likely wind direction.</p>	<p>The current design utilises the existing single point of access that currently serves the concrete batching plant. The Applicant and their consultants have attempted to engage with SFRS⁵ specifically in relation to access arrangements from a fire risk safety perspective regarding the single access point but no response on this specific matter could be provided, as the SFRS is currently in the process of forming a working group (see email correspondence in Appendix 1). The Applicant is committed to explore all potential access options and to continue to seek to engage with SFRS on this matter.</p>
<p>The Grid Scale Battery Energy Storage System planning - Guidance for FRS (2023) recommends that hydrant supplies for boundary cooling purposes should be located close to BESS containers and be able to deliver no less than 1,900 litres per minute for at least two hours.</p>	<p>The Drainage Impact Assessment submitted in support to the application demonstrates that the site is connected to the public water supply and that the nearest fire hydrant is located at the exiting site entrance at Mary Street. The Applicant will ensure that the nearest hydrant provides sufficient water capacity to meet the regulation requirements, prior to construction and therefore no water tanks are required. .</p>
<p>The design shall integrate fire hydrants and/or static water tanks depending on the site conditions and presence of a fire main. The placement of water</p>	<p>As stated above, the Drainage Impact Assessment submitted in support to the application demonstrates that the site is</p>

⁵ SFRS stands for Scottish Fire and Rescue Service

access points near to the BESS is critical for ensuring both effective firefighting and the safety of personnel. The distance requirement between water access point and BESS typically between 10 to 30 metres, though this can vary depending on site-specific conditions, the outcome of risk assessments and recommendations from the FRS.

connected to the public water supply and that the nearest fire hydrant is located at the exiting site entrance at Mary Street.

6.3 Design Review of Proposed Development layout from Fire Safety Perspective

The BESS design layout provided by Fig Power⁶ has been reviewed, Table 6-2 shows adherence with best practice and industry standards.

Table 6-2: Design Review of Proposed Development from Fire Safety Perspective

Design Review	Design Compliance
Connectivity to the public water supply.	The current planning design ⁷ does not include water tanks. However, it has been confirmed that the site will instead be connected to the public water supply and fire hydrants. Further details such as water flow rate requirements will be provided as design progresses through post-planning and detailed design stage.
Provision of on-site drainage system to manage water runoff from a potential thermal runaway event to protect the environment and prevent contamination of water sources.	A Drainage Impact Assessment has been prepared and is submitted in support of the application. This details that a SuDs attenuation basin will be provided on-site to manage surface water run-off. The Drainage Impact Assessment sets out that the basis will be fitted with a valve system that can be closed in the unlikely event of a thermal runaway event. This will allow the run-off water to be contained and assessed and if necessary treated.
Space for a Welfare Unit would be recommended to be provided on site, if required for operational purposes	<p>The Proposed Development will not have any permanent staff based at the site once it is operational. The BESS will be remotely monitored once operational. There is therefore no requirement to provide a welfare unit.</p> <p>An off-site welfare unit will be provided at the construction stage to provide facilities for the appointed contractor.</p>
A spares container is not strictly required for a BESS site, but recommended for larger sites.. This is not stipulated in NFPA 855 but the document does state the requirement to maintain high standards of safety, performance, and reliability. Critical	The inclusion of a spares container in the site boundary has been confirmed.

⁶ Drawing File: 000067-FIG-DR-0006_P03_Layout_Operation (002).pdf

⁷ Drawing File "Port Dundas BESS Layout-BESS Layout.pdf"

components for fire safety, thermal management, electrical integrity, and operational efficiency should be determined and be available on site to rapidly address potential system failures.	
The allowance of a space for service vehicle parking would be recommended.	Service vehicles attending the site for planned or reactive maintenance can be parked on the internal access road or at the site entrance at Mary Street. There is sufficient space within site boundary and at site access road to accommodate service vehicles attending the site
CCTV covering the BESS development area is strongly recommended to enhance site security.	CCTV will be provided at the site for security purposes and remote monitoring.

Appendix 1 Email Correspondence with FRS Department

From: David Fernandez
Sent: Tuesday, November 12, 2024 2:47 PM
To: 'Travers, Paul' <Paul.Travers@firescotland.gov.uk>
Cc: SFRS Water Planning <SFRS.WaterPlanning@firescotland.gov.uk>
Subject: RE: Battery Project Enquiry

Thanks Paul for coming back, so how long does it take for the go ahead for this project? how could this be discussed with the working group? Or shall I approach anyone in specific? Basically, I need to submit the BESS Safety Outline and normally a chapter regarding the Consultation with FRS is expected. If you prefer, I am happy to give you a call.

Regards,

David

From: Travers, Paul <Paul.Travers@firescotland.gov.uk>
Sent: Tuesday, November 12, 2024 2:13 PM
To: David Fernandez <david.fernandez@itpenergised.com>
Cc: SFRS Water Planning <SFRS.WaterPlanning@firescotland.gov.uk>
Subject: RE: Battery Project Enquiry

Hi David unfortunately I cannot make any decisions on these matters until I have the go ahead from the working groups looking into the NFCC guidance on BESS sites.

Regards,

Paul Travers

From: David Fernandez <david.fernandez@itpenergised.com>
Sent: 12 November 2024 10:17
To: Travers, Paul <Paul.Travers@firescotland.gov.uk>
Cc: SFRS Water Planning <SFRS.WaterPlanning@firescotland.gov.uk>; Kerri McGuire <Kerri.McGuire@g-s.co.uk>
Subject: RE: Battery Project Enquiry

Some people who received this message don't often get email from david.fernandez@itpennergised.com. [Learn why this is important](#)

CAUTION: This email originated from outside of SFRS. Do not click links or open attachments unless you are certain the email is genuine and know the content is safe.

Hi Paul, how are you? I am aware you have been on leave last week, thus I tried to call the Water Planning Department today unfortunately no success. However, happy to call at a time that may suit better. Mainly I looking for recommendations to the points described in the email below, your inputs are highly appreciated.

Regards,

David

David Fernandez

Associate Renewable Energy Consultant

M [+34 613 959 057](tel:+34613959057)

E david.fernandez@itpennergised.com

ITPENnergised

Brew House | Jacob Street | Tower Hill | Bristol | BS2 0EQ, Bristol, United Kingdom BS2 0EQ



Confidentiality

Notice

and

This communication, and any attachment(s) contains information which is confidential and may also be legally privileged. It is for the exclusive use of the recipient(s) to whom it is addressed. If you are not the intended recipient, any disclosure, copying, distribution or not taken in reliance on it is prohibited and may be unlawful. If you have received this communication in error, please advise the sender immediately by email and then delete the e-mail from your system. As e-mails and any information sent with them may be intercepted, corrupted and/or lost, we do not accept any liability for any errors or omissions in the message or any attachment howsoever caused. Any advice or opinion is provided on the basis that it has been prepared by SLR with reasonable skill, care and diligence, taking into account the manpower, timescales and resources devoted to it by agreement with its Client. It is subject to the terms and conditions of any agreement it relates. Parties with whom SLR is not in a contractual relationship in relation to the subject of the message should not use or rely on the information, advice, recommendations and opinions in this message and any attachment(s) for any purpose.

© 2020 SLR Consulting Limited. All Rights Reserved.

From: David Fernandez <david.fernandez@itpennergised.com>
Sent: Wednesday, November 6, 2024 12:30 PM

To: Travers, Paul <Paul.Travers@firescotland.gov.uk>
Cc: SFRS Water Planning <SFRS.WaterPlanning@firescotland.gov.uk>
Subject: RE: Battery Project Enquiry

Hi Paul, we have 2 queries regarding the project and your recommendations or views are appreciated:

- The 10 metre separation between BESS and combustible vegetation is challenging design requirement as landscaping will require to show a biodiversity enhancement to accord with National Planning Framework 4 (NPF4).
- The provision of two separate access points to the site is recommended, however based on the site characteristics this can not be provided. How could we deal with this? Perhaps undertaking some plume modelling to understand how gases and smoke will disperse?

Regards,

David

David Fernandez

Associate Renewable Energy Consultant

M [+34 613 959 057](tel:+34613959057)

E david.fernandez@itpenergised.com

ITPENergised

Brew House | Jacob Street | Tower Hill | Bristol | BS2 0EQ, Bristol, United Kingdom BS2 0EQ



Confidentiality

Notice

and

This communication, and any attachment(s) contains information which is confidential and may also be legally privileged. It is for the exclusive use of the recipient(s) to whom it is addressed. If you are not the intended recipient, any disclosure, copying, distribution or not taken in reliance on it is prohibited and may be unlawful. If you have received this communication in error, please advise the sender and then delete the e-mail from your system. As e-mails and any information sent with them may be intercepted, corrupted and/or lost, we do not accept any liability for any errors or omissions in the message or any attachment howsoever caused. Any advice or opinion is provided on the basis that it has been prepared by SLR with reasonable skill, care and diligence, taking into account the manpower, timescales and resources devoted to it by agreement with its Client. It is subject to the terms and conditions of any agreement it relates. Parties with whom SLR is not in a contractual relationship in relation to the subject of the message should not use or rely on the content of this communication.

information, advice, recommendations and opinions in this message and any attachment(s) for

© 2020 SLR Consulting Limited. All Rights Reserved.

From: Travers, Paul <Paul.Travers@firescotland.gov.uk>
Sent: Wednesday, October 9, 2024 12:09 PM
To: David Fernandez <david.fernandez@itpennergised.com>
Cc: SFRS Water Planning <SFRS.WaterPlanning@firescotland.gov.uk>
Subject: RE: Battery Project Enquiry

Hi David SFRS are assessing all BESS site applications at the moment and there has been a working group established to consolidate all our departments and provide unified responses to all applications. Until this group completes its work, NFCC Best Practice guidance on BESS should be followed.

Regards Paul

Regards,

Paul Travers

From: SFRS Water Planning <SFRS.WaterPlanning@firescotland.gov.uk>
Sent: Wednesday, October 9, 2024 10:48 AM
To: Travers, Paul <Paul.Travers@firescotland.gov.uk>; SFRS Operational Intelligence <SFRS.OIAdmin@firescotland.gov.uk>
Subject: FW: Battery Project Enquiry

Good morning Paul/OI,

Please see email chain for your info.

Thanks,

Kirsty

Water Planning Admin Team
Hydrants & Water Planning Department
Operational Planning
Prevention, Protection & Preparedness
4 Barr Street

Ardrossan

KA22 8HD

Tel: 01294 606821

Website: [Water Planning](#)



From: David Fernandez <david.fernandez@itpenergised.com>
Sent: 09 October 2024 09:53
To: SFRS Fire Engineering <SFRS.FireEngineering@firescotland.gov.uk>; Darrah, Stephen <Stephen.Darrah@firescotland.gov.uk>; SFRS Water Planning <SFRS.WaterPlanning@firescotland.gov.uk>
Subject: RE: Battery Project Enquiry

CAUTION: This email originated from outside of SFRS. Do not click links or open attachments unless you are certain the email is genuine and know the content is safe.

Many Thanks for your response Marishia, then happy to discuss with the Water Planning Team.

Kind Regards,

David Fernandez | Associate Renewable Energy Consultant | ITPenergised
Mobile: +34 (0) 613 959 057
Brew House | Jacob Street | Tower Hill | Bristol | BS2 0EQ

www.itpenergised.com

ITPenergised is part of SLR Consulting Limited and incorporates Energised Environments Limited, ITPE Ltd & Xero Energy Limited.



Follow us on LinkedIn

P Please consider the environment before printing this e-mail

The contents of this email are confidential to the intended recipient and may not be disclosed. Although it is believed that this email and any attachments are virus free, it is the responsibility of the recipient to confirm this. This email may contain confidential information. If received in error, please delete it without making or distributing copies. Opinions and information that do not relate to the official business of Energised Environments Limited registered at 93 South Woodside Road, Glasgow, G20 6NT or ITPE Ltd., registered at Brew House, Jacob Street, Tower Hill, Bristol, BS2 0EQ, or Xero Energy Limited, registered at 93 South Woodside Road, Glasgow, G20 6NT trading as ITP Energised, are not endorsed by the company or companies.

From: SFRS Fire Engineering <SFRS.FireEngineering@firescotland.gov.uk>
Sent: Wednesday, October 9, 2024 10:50 AM
To: David Fernandez <david.fernandez@itpennergised.com>; Darrah, Stephen <Stephen.Darrah@firescotland.gov.uk>; SFRS Water Planning <SFRS.WaterPlanning@firescotland.gov.uk>
Subject: RE: Battery Project Enquiry

Good morning David,

BESS sites enquiries are usually dealt with by our Water Planning Team SFRS.WaterPlanning@firescotland.gov.uk, I have included them in this response.

Kind regards

Marishia Stronach | Fire Engineering | Prevention and Protection | Scottish Fire and Rescue Service | North Head Quarters, Pitmedden Road, Dyce | Aberdeen | AB21 0DP |

Contact number: 01224 268236 | Email: Marishia.Stronach@firescotland.gov.uk



Please consider the environment before printing this e-mail.

From: David Fernandez <david.fernandez@itpennergised.com>
Sent: Tuesday, October 8, 2024 2:29 PM
To: Darrah, Stephen <Stephen.Darrah@firescotland.gov.uk>
Cc: SFRS Fire Engineering <SFRS.FireEngineering@firescotland.gov.uk>
Subject: RE: Battery Project Enquiry

CAUTION: This email originated from outside of SFRS. Do not click links or open attachments unless you are certain the email is genuine and know the content is safe.

Thanks Stephen.

Regards,

David Fernandez | **Associate Renewable Energy Consultant** | ITPEnergised
 Mobile: +34 (0) 613 959 057
 Brew House | Jacob Street | Tower Hill | Bristol | BS2 0EQ

www.itpenergised.com

ITPEnergised is part of SLR Consulting Limited and incorporates Energised Environments Limited, ITPE Ltd & Xero Energy Limited.



Follow us on LinkedIn

P Please consider the environment before printing this e-mail

The contents of this email are confidential to the intended recipient and may not be disclosed. Although it is believed that this email and any attachments are virus free, it is the responsibility of the recipient to confirm this. This email may contain confidential information. If received in error, please delete it without making or distributing copies. Opinions and information that do not relate to the official business of Energised Environments Limited registered at 93 South Woodside Road, Glasgow, G20 6NT or ITPE Ltd., registered at Brew House, Jacob Street, Tower Hill, Bristol, BS2 0EQ, or Xero Energy Limited, registered at 93 South Woodside Road, Glasgow, G20 6NT trading as ITPEnergised, are not endorsed by the company or companies.


From: Darrah, Stephen <Stephen.Darrah@firescotland.gov.uk>
Sent: Tuesday, October 8, 2024 2:38 PM
To: David Fernandez <david.fernandez@itpenergised.com>

Cc: SFRS Fire Engineering
Subject: RE: Battery Project Enquiry

<SFRS.FireEngineering@firescotland.gov.uk>

Hi David, many thanks for the information. I will forward your request to our Fire Engineering Department who have been cc'd into the email chain.

Best Regards,



Stephen Darrah

**Watch Commander | Fire Safety Enforcement Officer | Prevention, Protection & Preparedness | Cowcaddens
Fire Station | 91-123 Port Dundas Rd | Glasgow | G4 0ES**

E: stephen.darrah@firescotland.gov.uk **T:** 0141 302 3148 **M:** 07780 245155

www.firescotland.gov.uk



SCOTTISH
FIRE AND RESCUE SERVICE
Working together for a safer Scotland

Safety. Teamwork. Respect. Innovation.

From: David Fernandez <david.fernandez@itpenergised.com>
Sent: Tuesday, October 8, 2024 12:58 PM
To: Darrah, Stephen <Stephen.Darrah@firescotland.gov.uk>
Subject: RE: Battery Project Enquiry

CAUTION: This email originated from outside of SFRS. Do not click links or open attachments unless you are certain the email is genuine and know the content is safe.

Good Afternoon Stephen, thanks for your reply. I tried to call you but happy to give you a ring when suitable for you. The project is currently at a pre-planning stage, and basically the screening for the project is taking place. Therefore, the project is still in at an early stage and still to be confirmed if it goes ahead.

I am preparing what is called the Outline Battery Safety Management Plan, which is developed at an early project stage and where recommendations from local FRS are captured, to make sure that if the project progresses the potential Battery project that all aspects of battery safety, risks and compliance are addressed.

Regards,

David Fernandez | **Associate Renewable Energy Consultant** | ITPEnegised
 Mobile: +34 (0) 613 959 057
 Brew House | Jacob Street | Tower Hill | Bristol | BS2 0EQ

www.itpenegised.com

ITPEnegised is part of SLR Consulting Limited and incorporates Energised Environments Limited, ITPE Ltd & Xero Energy Limited.



Follow us on LinkedIn

P Please consider the environment before printing this e-mail

The contents of this email are confidential to the intended recipient and may not be disclosed. Although it is believed that this email and any attachments are virus free, it is the responsibility of the recipient to confirm this. This email may contain confidential information. If received in error, please delete it without making or distributing copies. Opinions and information that do not relate to the official business of Energised Environments Limited registered at 93 South Woodside Road, Glasgow, G20 6NT or ITPE Ltd., registered at Brew House, Jacob Street, Tower Hill, Bristol, BS2 0EQ, or Xero Energy Limited, registered at 93 South Woodside Road, Glasgow, G20 6NT trading as ITPEnegised, are not endorsed by the company or companies.

From: Darrah, Stephen
Sent: Tuesday, October 8,
To: David Fernandez
Subject: Battery Project Enquiry

<Stephen.Darrah@firescotland.gov.uk>
 2024 12:44 PM
 <david.fernandez@itpenegised.com>

Good morning David,

In reply to your enquiry listed below, I am initially looking to find out if the project is underway, has been completed or yet to start as this will have a little bearing on what information or to whom I can inform moving forward.

Enquiries

Subject: Enquiries

Name: David Fernandez

Email: david.fernandez@itpenergised.com

Phone:

Area: BESS Project Port Dundas - Consultation

Details: To whom it may concern, my name is David Fernandez and I work with a renewable energy consultancy named as ITPENERGISED and are currently involved in a preapplication process for a 90MW Battery Project in Port Dundas. It would be great if we could get into contact with the local fire and rescue service in the Area of Port Dundas, I tried with Cowcaddens Community Fire Station calling several times but no success. We would like to get into communication with FRS regarding recommendations if such as project would be developed. Kind Regards, David Fernandez | Associate Renewable Energy Consultant | ITP Energised Mobile: +34 (0) 613 959 057 www.itpenergised.com

Best Regards,



Stephen Darrah

Watch Commander | Fire Safety Enforcement Officer | Prevention, Protection & Preparedness | Cowcaddens Fire Station | 91-123 Port Dundas Rd | Glasgow | G4 0ES

E: stephen.darrah@firescotland.gov.uk **T:** 0141 302 3148 **M:** 07780 245155

www.firescotland.gov.uk



SCOTTISH
FIRE AND RESCUE SERVICE
Working together for a safer Scotland

Safety. Teamwork. Respect. Innovation.

E-mail confidentiality notice
The information contained in this message is confidential and intended for the addressee only. The unauthorised use, disclosure, copying or alteration of this message is prohibited. If you have received this e-mail in error, please reply to the sender immediately and delete the message.

E-mail confidentiality notice
The information contained in this message is confidential and intended for the addressee only. The unauthorised use, disclosure, copying or alteration of this message is prohibited. If you have received this e-mail in error, please reply to the sender immediately and delete the message.

E-mail confidentiality notice
The information contained in this message is confidential and intended for the addressee only. The unauthorised use, disclosure, copying or alteration of this message is prohibited. If you have received this e-mail in error, please reply to the sender immediately and delete the message.

E-mail confidentiality notice
The information contained in this message is confidential and intended for the addressee only. The unauthorised use, disclosure, copying or alteration of this message is prohibited. If you have received this e-mail in error, please reply to the sender immediately and delete the message.

E-mail confidentiality notice
The information contained in this message is confidential and intended for the addressee only. The unauthorised use, disclosure, copying or alteration of this message is prohibited. If you have received this e-mail in error, please reply to the sender immediately and delete the message.



ITPEnergised is a leading international consultancy delivering expert energy, environmental, engineering, technical advisory and asset management services; facilitating the transition to net zero.

Visit the ITPENERGISED group offices in:

Bristol, London, Edinburgh, Glasgow, Buenos Aires, Madrid, Delhi, Beijing, Canberra, Auckland

Sectors:

Onshore Renewables & Storage | Offshore Wind & Marine Renewables | Oil & Gas Transition
Property & Urban Regeneration | Corporate, Industrial & Manufacturing

